



THE TOWN OF  
**BOILING SPRINGS**

NORTH CAROLINA

---

Date: 01/05/2023

To: Kings Mountain Herald, C19tv, WOHS/WCSL, Shelby Star

From: Todd Humphries  
Wastewater Treatment Plant Supervisor / ORC, Town of Boiling Springs

Re: **Press Release**  
**Notification of Discharge of Untreated Wastewater**

General Statute 143-215.1C requires that the owner or operator of any wastewater collection or treatment works to issue a press release when an untreated wastewater discharge of 1,000 gallons or more reaches surface waters.

In accordance with that regulation, the following news release has been prepared and issued to the media in the affected county(ies): Cleveland

The Town of Boiling Springs had a discharge of untreated wastewater on 01/04/2023 estimated at 1800 gallons total from two manholes inside the campus area of Gardner Webb University into Lake Hollifield. The campus is located at 110 North Main Street Boiling Springs, NC 28017. The spill occurred due to inflow and infiltration (I&I) from an estimated 2.9 inches of rain. The untreated wastewater was discharged into Lake Hollifield. The Town of Boiling Springs is taking remedial measures to evaluate this area of wastewater lines and implement improvements to prevent this from occurring in the future.

The Division of Water Resources was notified of the event on 01/04/2023 at 2:20 pm and is reviewing the matter. For more information visit the Town's website at [www.boilingspringsnc.net](http://www.boilingspringsnc.net) or contact the Town of Boiling Springs Town Hall at (704) 434-2357.

Sincerely,

Justin E. Longino  
Town Manager